

Brian S. Marshall
Fire Chief & Director of Emergency Services

Kern County Fire Department - Hazard Reduction

20569 Eumatilla Street

Tehachapi, CA 93561

Email: hazardreduction@co.kern.ca.us

Telephone 661-823-1001 • FAX 661-823-1001



KERN COUNTY FIRE HAZARD REDUCTION PROGRAM MUST BE COMPLETED BY JUNE 15th



REQUIRED CLEARANCE GUIDELINES

- **100'** clearance around **ALL** structures. **Two zones** make up the required 100' of defensible space
- **Zone 1- 30'** from the structure, remove **ALL** combustible fuels in this area
- **Zone 2- 70'** extends to 100' from the structure, reduce **ALL** combustible fuels in this area
- **10'** clearance around **ALL** property lines
- **10'** clearance around stovepipe/chimney outlets
- **10'** clearance around LPG tanks
- **10'** clearance around **ALL** property lines of vacant lots and reduction of excessive accumulation of fuel declared to be a fire hazard within vacant lots
- Remove all dead limbs that are overhanging any structures
- Remove lower limbs of all **non-ornamental** trees to a height of 6' off the ground
- Clear roof of all combustible vegetation and debris

If you have any questions whether or not your property will pass inspection, please go to our website at www.kerncountyfire.org. Click on the Hazard Info tab > Hazard Reduction. Our website contains helpful information as well informative links regarding defensible space.

If you have any questions please call 661-823-1001 or email hazardreduction@co.kern.ca.us